

Certificate of Conformity

No. 230022RECO08-M3-CER

By the product certificate number:

Issued to:

License holder: **TommaTech GmbH**
 Angerlweg 14 c/o Kuhlmann, Tomma 85748
 Garching b. München, Germany

Trademark:



Contract number: **802595**

It is certified that the product:

Type of generating unit: **Hybrid inverter**

Models:	INV-TT-TF-M29.9K	INV-TT-TF-M30K	INV-TT-TF-M35K	INV-TT-TF-M40K	INV-TT-TF-M50K
Technical Data:					
Nominal power [kW]	29.9	30	35	40	50
Nominal voltage [V _{ac}]			230 / 400		
Nominal frequency [Hz]			50 / 60		
Firmware version			MAIN: Ver 3102		
Number of phases			Three Phase (3/N/PE)		
Isolation Transformer			No		

Is in compliance with the standard:

IEC 61727: 2004. "Photovoltaic (PV) systems – Characteristics of the utility interface."

This certificate is based upon the test results of the Test Report GZES221102230701 ⁽¹⁾

⁽¹⁾ The tests shown in this test report are carried out at a frequency of 50 Hz and 60 Hz

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-32 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 23rd January 2024

This certificate is valid until 16th May 2028

Madrid, 23rd January 2024

Daniel Arranz Muñiz
 Certification Manager

