

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Lithium-ion Rechargeable Battery System

Name and address of the applicant

TommaTech GmbH
Zeppelinstr. 14 - 85748 Garching b.München,
Germany

Name and address of the manufacturer

TommaTech GmbH
Zeppelinstr. 14 - 85748 Garching b.München,
Germany

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

 Additional Information on page 2
See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

Hera Indoor XkWh (X=80.3, 96.4, 112.5, 128.6, 144.6,
160.7, 176.8, 192.9, 208.9, 225.0, 241.1, 257.2)

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022
National Differences:

-

As shown in the Test Report Ref. No. which forms part of this Certificate


SZES260300186201

This CB Test Certificate is issued by the National Certification Body

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland

Date: 2026-04-24

Signature:


Mark Lohmann
Certification Manager

Ratings and principal characteristics:

Rated voltage and energy:

Hera Indoor 80.3kWh: 256,0 Vd.c., 80,3 kWh;
Hera Indoor 96.4kWh: 307,2 Vd.c., 96,4 kWh;
Hera Indoor 112.5kWh: 358,4 Vd.c., 112,5 kWh;
Hera Indoor 128.6kWh: 409,6 Vd.c., 128,6 kWh;
Hera Indoor 144.6kWh: 460,8 Vd.c., 144,6 kWh;
Hera Indoor 160.7kWh: 512,0 Vd.c., 160,7 kWh;
Hera Indoor 176.8kWh: 563,2 Vd.c., 176,8 kWh;
Hera Indoor 192.9kWh: 614,4 Vd.c., 192,9 kWh;
Hera Indoor 208.9kWh: 665,6 Vd.c., 208,9 kWh;
Hera Indoor 225.0kWh: 716,8 Vd.c., 225,0 kWh;
Hera Indoor 241.1kWh: 768,0 Vd.c., 241,1 kWh;
Hera Indoor 257.2kWh: 819,2 Vd.c., 257,2 kWh;

Rated capacity:

314 Ah

SGS Fimko Ltd
Takomotie 8
FI-00380 Helsinki, Finland



Date: 2026-04-24

Signature:



Mark Lohmann
Certification Manager