

Certificate of Conformity (COC)

SGS

Certificate Holder : TommaTech GmbH
Zeppelinstr. 14 85748 Garching b.München, Germany

Date of Original Issue : 2026-06-18


Date of Last Revision : --

Date of Expiry : 2029-06-17

Certificate Number : PCS-26-1130

Product : Hybrid Inverter

Ratings : See appendix on page 2 and page 3

Brand/Trademark : 
GERMAN-based company

Model : Trio Hybrid S 5K HV AIO, Trio Hybrid S 6K HV AIO, Trio Hybrid S 8K HV AIO,
Trio Hybrid S 10K HV AIO, Trio Hybrid S 12K HV AIO, Trio Hybrid S 15K HV AIO,
Trio Hybrid S 20K HV AIO, Trio Hybrid S 25K HV AIO

Test Laboratory : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch

Testing Report(s) : GZGC260500032501 and GZGC260500032502

Test Standard(s) : IEC 61727:2004 and IEC 62116:2014



This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).
The above-mentioned product is certified according to the requirements of ISO/IEC 17065:2012.

Christopher Hee
Certification Officer



SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way #03-01 Singapore 609957



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

Model	Trio Hybrid S 5K HV AIO	Trio Hybrid S 6K HV AIO	Trio Hybrid S 8K HV AIO	Trio Hybrid S 10K HV AIO
PV Input				
Max. Input Voltage (V)	1000			
Start-up Voltage (V)	180			
Rated Input Voltage(V)	600			
Full Power MPPT Voltage Range (V)	195~850	195~850	260~850	325~850
Max. Input Current (A)	20+20			
Max. Short Circuit Current (A)	30+30			
No. of MPP Trackers/ No. of Strings MPP Tracker	2/1+1			
Battery Input				
Battery Type	Lithium-ion			
Battery Voltage Range (V)	160~700			
Max. Charging/Discharging Current (A)	30	30	37	37
Number of Battery Input	1			
AC Output				
Nominal Grid Voltage (V)	3L+N+PE, 230/400			
Nominal Grid Frequency (Hz)	50/60			
Rated AC Power (kW)	5.0	6.0	8.0	10.0
Max. AC Apparent Power (kVA)	5.5	6.6	8.8	11.0
Rated AC Current (A)	7.3	8.7	11.6	14.5
Max. AC Current (A)	8.0	9.6	12.8	16.0
Output Power Factor	0.8 leading to 0.8 lagging			
General Data				
Operating Temperature Range	-40 °C ~ +60 °C (>+45 °C Derating)			
Protection Degree	IP65			
Protective Class	Class I			
Cooling Method	Natural Cooling		Intelligent Air Cooling	
Topology	Non-Isolated			



Model	Trio Hybrid S 12K HV AIO	Trio Hybrid S 15K HV AIO	Trio Hybrid S 20K HV AIO	Trio Hybrid S 25K HV AIO
PV Input				
Max. Input Voltage (V)	1000			
Start-up Voltage (V)	180			
Rated Input Voltage (V)	600	600	600	700
Full Power MPPT Voltage Range (V)	340~850	420~850	500~850	625~850
Max. Input Current (A)	26+20	26+20	26+26	26+26
Max. Short Circuit Current (A)	39+30	39+30	39+39	39+39
No. of MPP Trackers/ No. of Strings MPP Tracker	2/2+1		2/2+2	
Battery Input				
Battery Type	Lithium-ion			
Battery Voltage Range (V)	160~700			
Max. Charging/Discharging Current (A)	37			50
Number of Battery Input	1			
AC Output				
Nominal Grid Voltage (V)	3L+N+PE, 230/400			
Nominal Grid Frequency (Hz)	50/60			
Rated AC Power (kW)	12.0	15.0	20.0	25.0
Max. AC Apparent Power (kVA)	13.2	16.5	22.0	27.5
Rated AC Current (A)	17.4	21.8	29.0	36.3
Max. AC Current (A)	19.2	24.0	31.9	39.9
Output Power Factor	0.8 leading to 0.8 lagging			
General Data				
Operating Temperature Range	-40 °C ~ +60 °C (>+45 °C Derating)			
Protection Degree	IP65			
Protective Class	Class I			
Cooling Method	Intelligent Air Cooling			
Topology	Non-Isolated			

